आईआरईएल (इंडिया) लिमिटेड / IREL (India) Limited
रेअर अर्थ्स प्रभाग / Rare Earths Division,
उद्योगमंडल / Udyogamandal, कोची / Kochi,
केरला / Kerala - 683 501

टिप्पणी / N O T E तारीख / Date: 28.09.2026

विषय/Sub.: Request for approval to release Corrigendum the tender of MIXER SETTLERS FOR TERBIUM PRODUCTION FACILITY under IRELTDC

Ref: CPP Tender No.2026_IREL_290645_1 dt. 11.09.2026

Procurement of 09 Nos of mixer settlers for Terbium Production Plant facility is planned for which the tender was floated as per the cited reference.
One of the parties vide email dated 22-09-2026 has communicated to make some relevant changes in the floated specifications as the availability of motors will be difficult with the specified conditions.
It may be communicated to read the technical specification as under:-

1.0	Operating conditions	Continuous
	a. Rated Voltage & Frequency	415V + 10%,50Hz + 5%, 3 phase AC
	b. Maximum ambient temperature	500C
2.0	Motor details	
2.1	Type of motor	Energy efficient, Squirrel Cage Induction motor (type eff-2), 4 pole.
2.2	Rated output in HP	0.25
2.3	Rated speed in RPM	750 (synchronous speed) 680 slip speed
2.4	Tvpe of mounting	Vertical flanged (vertical down)
2.5	Class of duty as per IS:325	S1
2.6	Protection	IP55
2.7	Method of starting	To be furnished by driven equipment Vendor
2.8	Insulation class	Class F, but temperature rise limited to class B
2.9	Enclosure	TEFC
2.10	Location	Indoor
2.11	Make of motors	**Crompton / Kjrloskar / Havels / L&T/ ABB/NBE Motors or equivalent**

Therefore, it is requested to kindly approve to issue a corrigendum in this regard and extending the bid opening date till **12.10.2026.**

28/09/26

प्रबंधक - तकनीकी (क्यूसीएवंआर)
Manager - Technical (QC & R)

महाप्रबंधक&प्रधान(आर.ई.डी)-अनुमोदन के लिए प्रस्तुत
GM &Head (RED) - Submitted for kind approval

28/09/26